

**State of Arkansas
OFFICE OF STATE PROCUREMENT
1509 West Seventh Street, Room 300
Little Rock, Arkansas 72201-4222**

ADDENDUM #1

TO: Vendors Addressed

FROM: Lee Costley, Buyer

DATE: 03/04/2015

SUBJECT: SP-15-0074: EMERGENCY GENERATOR

The following changes to the above-referenced Invitation for bid for the **ARKANSAS DEPARTMENT OF CORRECTION** have been made as designated below:

BID OPENING TIME AND DATE REMAIN UNCHANGED: 03/19/2015 @ 1:00 P.M. CT

Delete: 2.06 SPECIFICATIONS: PAGES 8 AND 9 OF 13:

Replace with: 2.06 SPECIFICATIONS:

Kohler Emergency Generator Set, Model 275REOZJE-or approved equal.
280KW @ 120/208 VAC, 3 Phase, 60 HZ.
Diesel fueled engine operating at 1800 RPM.
DEC3000 digital control panel per NFPA-110 Level 1.
Electronic Isochronous engine speed governor.
Weather protective enclosure with Internally-mounted critical grade silencer.
1200 Amp main line circuit breaker 3 Pole, 600V, Square D, UL listed thermal magnetic type.
2500 watt block heater.
120VAC/ 1 Phase, battery charger, 6 Amp 120VAC/1 Phase with proper DC output as required by the engine.
470 Gallon (minimum) sub-base fuel tank, double wall construction UL 142 Listed. (minimum 27 hours @ 100% load)

Kohler automatic transfer switch model KEP-DMVC-1200S or approved equal.
(MUST BE INCLUDED WITH GENERATOR. GENERATOR AND SWITCH GEAR MUST BE COMPATIBLE).
1200 AMPS @ 120/208 VAC 3 Phase, 60Hz.
Programmed-Transition shall provide an adjustable time delayed center "OFF" position.
Service Entrance Rated Transfer with MPAC 1500 microprocessor controller with digital display.
Two-Position switch with pad-lockable cover shall disconnect the normal source and inhibit transfer during maintenance or service.
Isolating mechanism and over-current protection on the incoming utility supply.
A SEPARATE, UPSTREAM CIRCUIT BREAKER/DISCONNECT SWITCH IS NOT ACCEPTABLE.
Controller disconnect switch shall disconnect power to controller without disconnecting power to load.
The transfer mechanism shall consist of an 80% rated, molded case circuit breaker for the utility and a 100% rated molded case switch for the generator.
4 Pole with switched neutral.
Nema 3R enclosure for outdoor installation.
Upon delivery, awarded vendor shall furnish three (3) printed copies and one (1) electronic copy of owner/operator/service manual(s) for the equipment bid. Manual(s) shall be in the English language.

The specifications by virtue of this addendum become a permanent addition to the above-referenced Invitation for Bid. **FAILURE TO RETURN THIS SIGNED ADDENDUM MAY RESULT IN REJECTION OF YOUR BID.**

VENDOR SIGNATURE

DATE

COMPANY _____