



STATE OF ARKANSAS
OFFICE OF STATE PROCUREMENT
 1509 West 7th Street, Room 300
 Little Rock, Arkansas 72201-4222

ADDENDUM 1

TO: Vendors Addressed
 FROM: Heather Bailey, Buyer
 DATE: January 29, 2019
 SUBJECT: SP-19-0054 Residential Treatment Facilities Management

The following change(s) to the above-referenced RFP have been made as designated below:

- ☐ Change of specification(s)
- ☒ Additional specification(s)
- ☐ Change of bid opening time and date
- ☐ Cancellation of bid
- ☐ Other

ADDITIONAL SPECIFICATIONS

- Add the following to **SECTION 3 – FACILITY OPERATIONS AND USAGE REQUIREMENTS**:

3.9 STANDARD MAINTENANCE AND REPAIR

- G. Contractor **shall** maintain and keep operational the Sewer Treatment Facility located at the Lewisville Treatment Facility.
1. Chlorine Levels **must** be tested daily.
 2. Water samples **must** be sent to the Arkansas Health Department every month for bacteria testing.
 3. A major service **must** be performed every ten (10) years. The Sewer Treatment Facility was changed in 2016.
 4. Service **must** be done by a licensed operator.

The specifications by virtue of this addendum become a permanent addition to the above referenced RFP. Failure to return this signed addendum may result in rejection of your proposal.

If you have any questions please contact Heather Bailey at Heather.Bailey@dfa.arkansas.gov or (501) 324-9320.

Company: _____

Signature: _____

Date: _____